

Received: 07/02/2008	Completed: 07/02/2008	Letter: Z1	rb	P.O.#:	Test Report #:	2-74295-1-
Client's Identification	Layers Vineyard Large					
Tested For: Jenny Ayala					Key Test: NFPA 260 Cover Fabric (BLDG)	105
Maharam					Tel: 1-(631)-851-3215	Ext:
45 Rasons Court					Fax: 1-(631)-232-2659	
Hauppauge, NY 11788						

PC: 4H /jd

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:	TEST		RETEST (If Required)		
	Specimen #	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length On Vertical Panel (mm)
	1	SE	0	SE	0
	2	SE	0	No	22
	3	SE	0	No	20

ABBREVIATION WHICH MAY BE USED:

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75"). (Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75"). (Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating; Class II rating



Received:07/02/2008	Completed:07/02/2008	Letter: Z1	rb	P.O.#:	Test Report #:	2-74295-1-
Client's Identification	Layers Vineyard Large					
Tested For: Jenny Ayala Maharam 45 Rasons Court Hauppauge, NY 11788				Key Test: NFPA 260 Cover Fabric (BLDG)		105
				Tel: 1-(631)-851-3215		Ext:
				Fax: 1-(631)-232-2659		

CODE INFORMATION: In accordance with --

- (1) The 2006 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2.1(1);
- (2) The 2006 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1 and 805.3.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in:

Detention or correctional occupancy
Health care occupancy
Residential board & care occupancy

In certain situations an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather E. Robertson

AUTHORIZED SIGNATURE
THE GOVMARK ORGANIZATION, INC. /rb

HEATHER E. ROBERTSON

(Page 2 of 2)