

Received:01/11/2005 Completed:01/12/2005 Letter: E her P.O.#: Test Report #: 2-54751-0-

Client's Identification Coda

Tested For: **Ayeesha Jahi** Key Test: NFPA 260 Cover Fabric 80
 Maharam
 251 Park Avenue South Tel: 1-(212)-614-2980 Ext:
 New York, NY 10010 Fax: 1-(212)-982-9221

PC: 4H

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

RESULTS:

Specimen #	Ignition (yes/no/SE)	Char Length		RETEST (If Required)	
		On Vertical Panel (mm)	On Vertical Panel (mm)	Ignition (yes/no/SE)	On Vertical Panel (mm)
1	No	14			
2	No	14			
3	No	17			

SE: Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

REMARKS: None.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75").
 (Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75").
 (Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

CONCLUSION: Based on the above Results and Classification System, the item tested is assigned a:

Class I rating Class II rating

CODE INFORMATION: In accordance with the 2003 Edition of the NFPA Life Safety Code 101 paragraph 10.3.2(1), upholstered furniture components shall be Class I when tested in accordance with NFPA 260, when used in health care, detention, and correctional occupancies. In certain situations, an exception is made if the rooms or areas are sprinklered.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by NFPA 260.

Heather E. Robertson

MS. HEATHER ROBERTSON

AUTHORIZED SIGNATURE
 THE GOVMARK ORGANIZATION, INC. /jdAH

(Page 1 of 1)